

Water Quality Association

04/27/2009

NSF/ANSI-61 International Standard for Drinking Water Additives

NSF/ANSI-61 Drinking Water System Components - Health Effects

This Standard establishes minimum health effects requirements for the chemical contaminants and impurities that are indirectly imparted to drinking water from products, components, and materials used in drinking water systems. This Standard does not establish performance, taste and odor, or microbial growth support requirements for drinking water systems products, components, or materials.

CWG USA LLC

662 Harbor Road, Suite 440

Destin, FL 32541

Phone: (850) 837-2619

Product Type: Ion Exchange Resin

<i>Brand Name</i>	<i>Model</i>	<i>Size</i>	<i>Water Contact Temp</i>	<i>Water Contact Material</i>	<i>CA AB1953 Compliant</i>
N/A	Filtersorb IR ¹⁷⁶	500 - 1000 microns	CLD 23	SYN	Not Evaluated
N/A	Filtersorb SP3 ¹⁷⁶	500 - 1000 microns	CLD 23	SYN	Not Evaluated

¹⁷⁶: This product has a minimum flow rate requirement of 5.1 gpm per cubic foot of media.

[Back](#)

Disclaimer:

Listing in these directories does not constitute an endorsement, guarantee, or warranty of any kind by Water Quality Association or its members of any of the products contained in them. Every effort has been made to verify the accuracy of all listings in this directory. The association can assume no liability for errors or omissions.

Water Quality Association:

 [Back](#)

Mon, Apr 27, 2009

Copyright 2009 by the Water Quality Association – All rights reserved.

Water Quality Association

International Headquarters & Laboratory

4151 Naperville Road

Lisle, IL 60532-3696

USA

630 505 0160, Fax 630 505 9637

info@wqa.org, www.wqa.org

[Disclaimers](#)